



27th April 2021

TO WHOM IT MAY CONCERN

This is to certify that Indian Language School building located at 14/16 Nle Aro Avenue, Ilupeju Lagos, is structurally safe as per the investigation done for non-destructive test on 26th of April 2021 for the existing frame building (Ground, First, Second and Third floor). The average compressive strength is 42N/mm² which is above the design load of 30N/mm²

The domestic waste and storm water discharged externally is found adequate as per local norms and not hazardous to the environment.

The portable water is filtered through domestic water fitter and found to be healthy for consumption.

Sincerely,

Pramod Thorat

B.E(Civil), NICMAR



PRINCIPAL
INDIAN LANGUAGE SCHOOL
14/18 OBA NLE-ARO AVENUE,
ILUPEJU
P. O. BOX 8240 LAGOS

CC: The Principal Indian Language School Lagos.

Attached: Schmidt Hammer test results and pictures.

Shapoorji Pallonji Nigeria Limited

RC 955686

Suite No. 7, 3rd Floor, Eleganza Biro Plaza, Plot 634
Adeyemo Alakija Street, Victoria Island, Lagos Nigeria
(T) +234 70463331; +2348052294779.
www.shapoorji.in